

Exova Warringtonfire
Holmesfield Road
Warrington
WA1 2DS
United Kingdom

T : +44 (0) 1925 655 116
F : +44 (0) 1925 655 419
E : warrington@exova.com
W: www.exova.com



Testing. Advising. Assuring.

Title:

CLASSIFICATION REPORT
FOR ROOFS/ROOF
COVERINGS EXPOSED TO
EXTERNAL FIRE
EN 13501-5: 2005 +A1:
2009

Notified Body No:

0833

Product Names:

A built up roof system
incorporating solar panel
referenced "Trina Solar TSM
DC05A.08"

Report No:

WF 372636

Issue No:

1

Prepared for:

SVH Energie
155 Rue Du Docteur Bauer
93400 Saint Ouen
France

Date:

24th October 2016



1. Introduction

This classification report defines the classification assigned to a built up roof system incorporating solar panel referenced "Trina Solar TSM DC05A.08", which is fully described in paragraph 2.2, in accordance with the procedures given in EN 13501-5: 2005: + A1: 2009

2. Details of classified product

2.1 General

The product, a built up roof system incorporating solar panel referenced "Trina Solar TSM DC05A.08", is defined as being suitable for roof covering applications.

2.2 Product description

The product, a built up roof system incorporating solar panel referenced "Trina Solar TSM DC05A.08", is fully described below and in the test reports provided in support of classification listed in Clause 3.1.

General description		In-roof mounting system for a solar panel
Product reference of overall composite		No product reference was assigned to this product
Name of manufacturer of overall composite		GSE
Thickness of overall composite		See Note 1 Below
Weight per unit area of overall composite		See Note 1 Below
Solar panel	Generic type	Solar panel
	Product reference	"Trina Solar TSM DC05A.08"
	Detailed description	Solar panel made of aluminium, glass and monocrystal
	Name of manufacturer	Trina Solar
	Thickness	35mm
	Weight per unit area	See Note 1 Below
	Flame retardant details	See Note 2 Below
Concrete tile	Generic type	Concrete roofing tile
	Product reference	"Marley Mendip Roofing Tile"
	Name of supplier	"Marley Mendip"
	Colour reference	"Brown"
	Dimensions	30mm x 340mm 60mm to height of profile)
	Weight per unit area	32kg/m ²
	Flame retardant details	See Note 2 Below
Moulded tray	Generic type	Polypropylene
	Product reference	"GSE Portrait 1640/992"
	Name of manufacturer	GSE
	Thickness	13mm
	Weight per unit area	2.5kg/m ²
	Colour reference	"Black"
	Flame retardant details	See Note 2 Below

Continued on next page

Timber battens	Generic type	Wood battens
	Product reference	"Pine Tree Battens"
	Name of manufacturer	See Note 3 Below
	Dimensions	25mm x 45mm
	Density	380kg/m ³
	Colour reference	"Natural"
	Flame retardant details	See Note 2 Below
Roofing felt	Generic type	Roof underlay
	Product reference	"Easytrim Master Breather Membrane"
	Name of supplier	Travis Perkins
	Colour reference	"Grey"
	Thickness	0.4mm
	Weight per unit area	117.5g/m ²
	Flame retardant details	See Note 2 Below
Timber joist	Generic type	Wood battens
	Product reference	"Pine Tree Battens"
	Name of manufacturer	See Note 3 Below
	Dimensions	45mm x 95mm
	Density	380kg/m ³
	Colour reference	"Natural"
	Flame retardant details	See Note 2 Below
Brief description of manufacturing process		See Note 3 Below

Note 1: The sponsor was unable to provide this information.

Note 2: The sponsor of the test has confirmed that no flame retardant additives were utilised in the production of the product / component.

Note 3: The sponsor was unwilling to provide this information.

3. Test reports & test results in support of classification

3.1 Test reports

Name of Laboratory	Name of sponsor	Test reports/extended application report Nos.	Test method / extended application rules & date
Exova Warringtonfire	SVH Energie	WF 364794	ENV 1187:2002 Test 4

3.2 Test results

3.2.1 Test 4

Test pitch: 45 degrees

Substrate/Deck: N/A

Supporting structure: Timber Joist

Preliminary test (Stage 1):

Parameter	Criteria	Test Results	Compliance
	Class B _{ROOF} (t4)	Specimen 1	Class B _{ROOF} (t4)
Burn time	<5min	NIL	Y
Flame spread distance	<0,38m	NIL	Y
Penetration	None	None	Y

Penetration test (Stage 2):

Parameter	Criteria	Test Results				Compliance
	Class B _{ROOF} (t4)	Specimen 1	Specimen 2	Specimen 3	Mean ^a	Class B _{ROOF} (t4)
Penetration time	≥60min	60min	60min	60min	60min	Y

^a If one or two of the specimens have not failed at one hour, a time of 60min shall be used in calculating the mean time of penetration.

4. Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with EN 13501-5: 2005: + A1: 2009

4.2 Classification

The product, a built up roof system incorporating solar panel referenced "Trina Solar TSM DC05A.08", in relation to its external fire performance is classified:

B_{ROOF} (t4)

4.3 Field of application

This classification is valid for the following conditions:

Range of pitches	>10 degrees
Substrate/Deck	N/A
Product configuration	No variation allowed
Product composition	No variation allowed
Product construction	No variation allowed
Product thickness	No variation allowed
Supporting structure	No variation allowed

5. Limitations


This document does not represent type approval or certification of the product.

SIGNED



.....
Mathew Dale
Senior Certification Engineer
Technical Department

APPROVED



.....
Janet Murrell
Technical Manager
Technical Department
on behalf of:
Exova Warringtonfire

This copy has been produced from a .pdf format electronic file that has been provided by **Exova Warringtonfire** to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of **Exova Warringtonfire**. The pdf copy supplied is the sole authentic version of this document. All pdf versions of this report bear authentic signatures of the responsible **Exova Warringtonfire** staff.